

ADDENDUM NO. 2

DATE: July 23, 2019

PROJECT: Denton County RFP 19-2534
Denton County Kitchen/Laundry

HDR Project No. 10105890

NOTICE:

THIS ADDENDUM IS ISSUED BY ARCHITECT TO ALL KNOWN INDIVIDUALS, FIRMS OR CORPORATIONS WHO HOLD BIDDING AND CONTRACT DOCUMENTS FOR ABOVE LISTED PROJECT.

THIS ADDENDUM IS HEREBY MADE A PORTION OF BIDDING AND CONTRACT DOCUMENTS, AS APPROPRIATE. ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN APPROPRIATE SPACE ON BID FORM.

HDR ARCHITECTURE, INC.

Matthew G. Palazzetti

7-23-19


William Edward Prindle II
7/23/19

ADDENDUM 2 (AD-2)

<u>INDEX</u>	<u>PAGE</u>
Revisions to Project Manual.....	3
Revisions to Civil Drawings (CD-2.1)	4
Revisions to Architectural Drawings (AD-2.1 through AD-2.3).....	5
Revisions to Mechanical Drawings (MD-2.1).....	6
Revisions to Plumbing Drawings (PD-2.1)	7
Attachments:	
Specifications	
Drawings	

ADDENDUM 2 (AD-2)
REVISIONS TO PROJECT MANUAL

1.1 GENERAL NOTE

- A. If paragraph has changed by this addendum, entire page (or entire section) has been reprinted. “AD” helps indicate line changed. Contractor is responsible for review of entire page to determine all changes made within paragraph.

- B. The following Documents or Sections have changed:
 - 1. Section 00 11 19, Section Revised
 - 2. Section 00 21 16, Section Revised
 - 3. Section 00 31 32, Section Revised
 - 4. Section 00 42 16, Section Revised
 - 5. Section 01 14 16, Section Revised
 - 6. Section 01 21 13, Section Revised
 - 7. Section 09 67 14, Section Revised
 - 8. Section 26 41 13, Section Revised
 - 9. Section 32 31 15, Section Revised

REVISIONS TO CIVIL DRAWINGS

AD-2, Item CD-2.1

Sheet C-200

1. Sheet removed from set

REVISIONS TO ARCHITECTURAL DRAWINGS

AD-2, Item AD-2.1

Cover Sheet

1. Modified to show drawings revised in Addendum number 2

AD-2, Item AD-2.2

Sheet AD-102 – FIRST FLOOR DEMOLITION PLAN, ELEVATIONS, AND DETAILS

1. Added Note for coordination of Door and Frame Demolition in Existing Jail Tower

AD-2, Item AD-2.3

Sheet FS. 01 – FOOD SERVICE KITCHEN AND LAUNDRY EQUIPMENT PLAN

1. Remove existing sheet FS.01 (untitled) and replace with FS.01 – Attached – to clarify missing information due to printing error

REVISIONS TO MECHANICAL DRAWINGS

AD-2, Item MD-2.1

Sheet MH-101A

1. Added fire damper to the sidewall supply grill serving Mechanical Room L-104

REVISIONS TO PLUMBING DRAWINGS

AD-2, Item PD-2.1

Sheet P-701

1. Updated notes 1 through 3 under PLUMBING FIXTURE CONNECTION SCHEDULE
2. Updated note 1 under KITCHEN EQUIPMENT CONNECTION SCHEDULE
3. Updated note 1 under PUMP SCHEDULE
4. Updated note 1 under WATER SOFTENER SCHEDULE