



THE COUNTY OF GALVESTON

RUFUS G. CROWDER, CPPO, CPPB
PURCHASING AGENT

GWEN MCLAREN, CPPB
ASST. PURCHASING AGENT

COUNTY COURTHOUSE
722 Moody (21st Street)
Fifth (5th) Floor
GALVESTON, TEXAS 77550

October 19, 2020

PROJECT NAME: Galveston County Road & Bridge Facility Rebuild Project

SOLICITATION NO: ITB #B201044

RE: ADDENDUM #6

To All Prospective Proposers:

The following information is being provided to aid in preparation of your bid submittal(s):

Question #1: *The metal building specifications call for the roof and wall panels to be 22 gauge, Mica Fluoropolymer finish. This is a non-standard panel gauge and finish. Is it acceptable to use the more industry standard 24 gauge, standard TWO coat kynar finish?*

Response: It is not acceptable. The General Contractor shall provide the panel finish and thickness called-out in the drawings.

Question #2: *There is a spec section 33 21 00 Water Supply Wells. Does this apply to this project? There is a note in this spec to reference Section 012100 Allowances, there is no Section 012100.*

Response: No spec "33 21 00 Water Supply Wells" has been issued for this project. Please ensure you are bidding the correct project manual.

Question #3: *Please confirm there are no Allowance and no Unit Prices to be included in our proposal.*

Response: That is correct.

Question #4: *Who is responsible for Utility Tap Fees/Impact Fees?*

Response: General Contractor will be responsible for these fees.

Question #5: *Who is responsible for Building Permit Fees?*

Response: The General Contractor is responsible for the Building Permit Fees.

Question #6: *Has an asbestos survey been done?*

Response: As asbestos survey has not been done. However, none of the existing buildings are being renovated; they are all being demolished.

Question #7 *Is the Owner providing and installing the Rail Crane? The rail is shown but no crane is specified.*

Response: The rail crane will be reused from the existing installation. This is an owner-furnished item. However, the GC will be responsible for demounting, moving, and reinstalling the rail crane in the new location.

As a reminder, all questions regarding this bid must be submitted in writing to:

Rufus G. Crowder, CPPO CPPB
Galveston County Purchasing Agent
722 Moody, Fifth (5th) Floor
Galveston, Texas 77550
E-mail: purchasing.bids@co.galveston.tx.us

or contact the Purchasing Department at (409) 770-5371.

Please excuse us for any inconvenience that this may have caused.

Sincerely,



Rufus G. Crowder, CPPO CPPB
Purchasing Agent
Galveston County

Addendum

Distribution	<input type="checkbox"/> Owner	<input type="checkbox"/> Consultant(s)	<input checked="" type="checkbox"/> Bidders	<input type="checkbox"/> Other ..
From	Wendy Heger, AIA Page Southerland Page, Inc. 1100 Louisiana Street Suite One Houston, TX 77002	Owner	Galveston County 722 Moody Avenue 6 th Floor Galveston, TX 77550	
Project	Galveston County Road & Bridge Department Facilities 5115 TX-3 Dickinson, TX 77573	Architect's Project No.	418198	
Date of Issue	19-October-2020	Addendum No.	006	
Contract For	General Construction	For Bids Due	29-October-2020	

Seals



Firm Registration No. 15868
Page Southerland Page, Inc

Description	This Addendum does not include changes to the Work:
Revised Documents	This Addendum does not include revised documents.
Additional Documents	Responses to Bidders Questions

This Addendum is hereby incorporated into the Contract Documents for the Project referenced above, modifying and superseding any previously issued Contract Documents. Bidders must acknowledge receipt of **Addendum 006** in the bid form.